

Proposal 22763
Electrical upgrade for Fort Dodge Garage
Questions and Responses Set 1

Q1) The 400 Amp main that we would be feeding the new panel is out of date, and hard to find parts for.

R1) See addendum 1

Q2) Could not get into the panel to look so I did not open the panel while I was at the site, but it didn't look like there was a spare breaker, and there were no 200Amp breakers in the panel

R2) See addendum 1